## Model DC65D

Page 1

## STANDARD CONSTRUCTION

| CONSTRUCTION   |
|--|
| .081" thk. (nominal) extruded aluminum, 6063-T52/T6 alloy.             |
| Channel type.  |
| Stationary blades are made from .081" thk. (nominal)                   |
| extruded aluminum 6063-T52/T6 alloy. Adjustable Blades                 |
| are made from .125" thk. (nominal) extruded aluminum                   |
| $6063-T52/T6$ alloy. Blades are approximately $4\frac{1}{2}$ on        |
|  |
| centers.   |
| Full width sill with head and blades contained within jambs.           |
| .50" dia. aluminum "Pin-Lock" rod.                                     |
| Extruded aluminum, concealed in the channel out of                     |
| the airstream. The pivots, which rotate in Celcon bearings,            |
| are .50" dia. plated and machined steel. The pivots is                 |
| locked to the ⁵⁄₁₅" dia. aluminum linkage rod by a ¼ - 20 set          |
| screw with epoxy locking patch.  |
| Extruded silicone rubber seals at blade edge. Foam on                  |
| bottom blade. Stainless steel at jambs.                                |
| (When indicated, in a removable frame)                                 |
| $\frac{1}{2}$ " flattened aluminum, .051" thk.,                        |
| Insect screen <sup>18</sup> / <sub>16</sub> aluminum mesh, .011" dia., |
|  |
| <sup>1</sup> / <sub>2</sub> " sq. mesh intermediate double crimped     |
| aluminum wire, .063" dia.  |
| Mill.  |
| TIONS  |
|  |

Finishes - Enamels, Epoxies, etc. Other screens available. Actuators - Electric, Pneumatic, Manual, etc.


## NOTES


1. Nominal deductions will be made to the opening size given.

2. Approximate shipping weight is 5.7 lbs./sq.ft.

# LOUVER SIZES

| Min Panel   | Max Single Panel |
|-------------|------------------|
| 12"W x 12"H | 48"W x 96"H      |





Louver Height (in.)

4½"

| Item #   | Qty    | Width  | Height  | Width | Height  | Mullion | Туре    | Location |      | NAL STATE         |
|----------|--------|--------|---------|-------|---------|---------|---------|----------|------|-------------------|
| Item #   |        | Openir | ng Size | Louve | er Size | Mullion | Screens |          |      | <u>Union Made</u> |
| Arch. /  | Eng. : |        |         |       |         | EDR:    |         | ECN:     | Job: |                   |
| Contr    | actor: |        |         |       |         |         |         |          |      |                   |
| Project: |        |        |         |       |         | Date:   |         | DWN:     | DWG: |                   |
|          |        |        |         |       |         |         |         |          |      |                   |

In the interest of product development, Louvers & Dampers reserves the right to make changes without notice.

Louvers & Dampers

6'

www.louvers-dampers.com

Not to scale

## DC65D odel

Water Penetration

Model DC65D

Test Unit Size

48" x 48'

## Page 2

## Extruded Aluminum Louver • 6" Deep • 35° Drainable Blades • Combination Adjustable

.30

.28

.26

.24

.22 .20

.18

.16 14

.12

.10

.08 ř

(oz./ft.) Free Area - 15 Minute Interval

## **PERFORMANCE DATA**

Pressure Drop:

.11 in. w.g. at 1029 fpm (intake)

Free Area: Beginning Point of Water Penetration: 8.24 sq.ft. = 52% for 48"W x 48"H sample tested in accordance with AMCA Standard 500-L. 1029 fpm

Ratings do not include the effects of a screen Pressure Drop .50 Model DC65D .40 Test Unit Size 48" x 48' .30 .20 Pressure Drop (in. w.g.) .10 .09 .08 .07 .06 .05 .04 .03 .02 .01 ġ

| F           |  |      |                 |            |              |       | Wate  | .06  |  | - |  |  |  |
|-------------|--|------|-----------------|------------|--------------|-------|-------|--|--|---|--|--|--|
| F           |  |      |                 |            |              |       | \$    | .04  |  |   |  |  |  |
| ╀           |  |      | ++++            |            |              |       |       | .04  |  | _ |  |  |  |
| t           |  |      | ++++            | ++++       |              | +++++ |       | .02  |  | _ |  |  |  |
| t           |  | +++  | ++++            |            |              |       |       |  |  | - |  |  |  |
| 1           | 4 5 6 7 8 9 10 12 14 16 18 20 900<br>Velocity (fpm) x 100 thru Free Area |      |                 |            |              |       |       |  | ) 1000 1100<br>Velocity (fpm) thru Free Area   | - |  |  |  |
|             |  | 5 (1 | ,<br><u>Fre</u> | e Area (so | <u>q.ft)</u> |       | _     | 1029 (FPM) Beginning Point of Water Penetration. |  |   |  |  |  |
| Width (in.) |  |      |                 |            |              |       |       |  |  |   |  |  |  |
|             | 12"  | 18"  | 24"             | 30"        | 36"          | 42"   | 48"   |  | *Intake air converted to standard air density.<br>Tested to AMCA Standard 500-L, Figure 5.5. |   |  |  |  |
|             | .14  | .24  | .34             | .45        | .55          | .65   | .76   |  |  |   |  |  |  |
|             | .64  | 1.12 | 1.60            | 2.08       | 2.55         | 3.03  | 3.51  |  |  |   |  |  |  |
|             | 1.00   | 1.76 | 2.51            | 3.26       | 4.02         | 4.77  | 5.52  |  | amca   |   |  |  |  |
|             | 1.50   | 2.62 | 3.74            | 4.87       | 5.99         | 7.11  | 8.24  |  | WORLDWIDE  |   |  |  |  |
|             | 2.00   | 3.50 | 4.99            | 6.49       | 7.99         | 9.49  | 10.99 |  | ROTIOGS  |   |  |  |  |

Air Leakage with adjustable blade in closed position with a seating torque of 6.25 in.lb./sq.ft. of Louver Face Area. Leakage is based on a test of a 48" x 48" louver. Air leakage (Louver Installation Position, Intake) is per

5.91


7.14

8.39

7.68

9.28

10.91



www.louvers-dampers.com

12" 24" 36"

48"

60"

72"

84"

96"

2.36

2.86

3.36

4.14

5.00

5.87

Height (in.



AIR

MOVEMENT

AND CONTROL

ASSOCIATION

INTERNATIONAL. INC.®

PERFORMANC

**Q**07

1200

Louvers & Dampers certifies that the Model DC65D shown herein is licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to Air Performance and Water Penetration Ratings only.

