


Model RS-7315
7" (177.8 mm) Storm Resistant Fixed Horizontal Louvre

Material:

Material:	6063-T6 Alloy
Nominal Thickness (heads, sills, jambs, & mullions):	0.068" (1.73 mm)
Nominal Blade Thickness:	0.068" (1.73 mm)
Furnished With:	Birdscreen: ½" intercrimp aluminum mesh, 0.063" diameter wire removeable aluminum bird screen in an aluminum frame
Additional Options (at additional cost):	Insect screen (in lieu of bird screen), Continuous clip angles for attachment Sheet blank off, Insulated blank off Sill pans, Flange frames Integrated glazing frames



Test Summary:
For a 4 Foot by 4 Foot Unit.

Tested with mill finish and no screen

- Free area = 8.09 ft² (0.751 m²)
- Percent free area = 50.5%
- Intake pressure drop at 1000 FPM free area velocity = 0.40 in H₂O (100.3 Pa)
- To maintain a CLASS A (99%) effectiveness rating* with:
 - a 29 mph wind speed and rainfall rate of 3 in/hr
 - Max. intake core velocity 1.5 m/s (283 FPM)
 - Max. intake free area velocity 2.9 m/s (567 FPM)

Discharge Coefficient
 Intake Cd = 0.24 (Class 3)
 AMCA certifies the coefficient class only



Construction Specialties Australia Pty Ltd certifies that the louvre model RS-7315 shown herein is licensed to bear the AMCA Seal.

The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified ratings Program. The AMCA Certified Ratings Seal applies to wind driven rain and air performance ratings.

Wind Driven Rain Performance: Tested with 1m² core area, mill finish and no screen*


29.1 mph (13 m/s) & 3" (75 mm) rain per hour

Core Velocity Through Cal. Plate (m/s):	0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5
Core Velocity Through Louvre (ft/min):	0	132	196	283	375	468	587	673
Free Area Velocity (ft/min):	0	264	392	567	751	937	1175	1347
Rating Effectiveness:	A	A	A	A	B	C	D	D
Effectiveness Ratio (%):			100	99.8	97	92.1	72.9	57.4
Effectiveness Rating:	A = 1 to 0.99		B = 0.989 to 0.95		C = 0.949 to 0.80		D = Below 0.80	

Model RS-7315
7" (177.8 mm) Storm Resistant Fixed Horizontal Louvre

Water Penetration Statement

AMCA defines the point of beginning water penetration as the free area velocity at which the AMCA water test has yielded 0.01 or less ounces of water per square foot of louvre free area during a 15-minute test period.



Air Velocity in Feet and Metres per Minute Through Free Area

Data corrected to standard air density.
 48" x 48" louvre tested to figure 5.5.

Free Area Table (Free area in sq. feet and sq. metres)

For additional sizes, please visit:

<https://www.c-sgroup.com/architectural-louvers/louvers-airflow-tool>

Height in Inches and Metres	Width in Inches and Metres								
	18	24	30	36	42	48	54	60	66
0.46	0.61	0.76	0.91	1.07	1.22	1.37	1.52	1.68	
18	0.73	1.02	1.32	1.61	1.91	2.21	2.50	2.80	2.94
0.46	0.07	0.09	0.12	0.15	0.18	0.20	0.23	0.26	0.27
24	1.21	1.70	2.20	2.69	3.18	3.68	4.17	4.66	4.91
0.61	0.11	0.16	0.20	0.25	0.30	0.34	0.39	0.43	0.46
30	1.45	2.05	2.64	3.23	3.82	4.41	5.00	5.59	6.18
0.76	0.14	0.19	0.24	0.30	0.35	0.41	0.46	0.52	0.57
36	1.94	2.73	3.52	4.30	5.09	5.88	6.67	7.46	7.85
0.91	0.18	0.25	0.33	0.40	0.47	0.55	0.62	0.69	0.73
42	2.18	3.07	3.95	4.84	5.73	6.62	7.50	8.39	8.83
1.07	0.20	0.28	0.37	0.45	0.53	0.61	0.70	0.78	0.82
48	2.67	3.75	4.83	5.92	7.00	8.09	9.17	10.25	10.80
1.22	0.25	0.35	0.45	0.55	0.65	0.75	0.85	0.95	1.00
54	2.91	4.09	5.27	6.46	7.64	8.82	10.00	11.19	11.78
1.37	0.27	0.38	0.49	0.60	0.71	0.82	0.93	1.04	1.09
60	3.39	4.77	6.15	7.53	8.91	10.29	11.67	13.05	13.74
1.52	0.32	0.44	0.57	0.70	0.83	0.96	1.08	1.21	1.28
66	3.63	5.11	6.59	8.07	9.55	11.03	12.51	13.98	14.72
1.68	0.34	0.47	0.61	0.75	0.89	1.02	1.16	1.30	1.37
72	4.12	5.79	7.47	9.15	10.82	12.50	14.17	15.85	16.69
1.83	0.38	0.54	0.69	0.85	1.01	1.16	1.32	1.47	1.55
78	4.60	6.48	8.35	10.22	12.09	13.97	15.84	17.71	18.65
1.98	0.43	0.60	0.78	0.95	1.12	1.30	1.47	1.65	1.73
84	4.85	6.82	8.79	10.76	12.73	14.70	16.67	18.64	19.63
2.13	0.45	0.63	0.82	1.00	1.18	1.37	1.55	1.73	1.82
90	5.33	7.50	9.67	11.84	14.00	16.17	18.34	20.51	21.59
2.29	0.50	0.70	0.90	1.10	1.30	1.50	1.70	1.91	2.01
96	5.57	7.84	10.11	12.37	14.64	16.91	19.17	21.44	22.57
2.44	0.52	0.73	0.94	1.15	1.36	1.57	1.78	1.99	2.10
102	6.06	8.52	10.99	13.45	15.91	18.38	20.84	23.31	24.54
2.59	0.56	0.79	1.02	1.25	1.48	1.71	1.94	2.17	2.28
108	6.30	8.86	11.43	13.99	16.55	19.11	21.68	24.24	25.52
2.74	0.59	0.82	1.06	1.30	1.54	1.78	2.01	2.25	2.37
114	6.78	9.54	12.30	15.06	17.82	20.58	23.34	26.10	27.48
2.90	0.63	0.89	1.14	1.40	1.66	1.91	2.17	2.42	2.55
120	7.03	9.88	12.74	15.60	18.46	21.32	24.18	27.03	28.46
3.05	0.65	0.92	1.18	1.45	1.71	1.98	2.25	2.51	2.64
126	7.51	10.57	13.62	16.68	19.73	22.79	25.84	28.90	30.43
3.20	0.70	0.98	1.27	1.55	1.83	2.12	2.40	2.68	2.83
132	7.75	10.91	14.06	17.22	20.37	23.52	26.68	29.83	31.41
3.35	0.72	1.01	1.31	1.60	1.89	2.19	2.48	2.77	2.92
138	8.24	11.59	14.94	18.29	21.64	24.99	28.34	31.70	33.37
3.51	0.77	1.08	1.39	1.70	2.01	2.32	2.63	2.94	3.10
144	8.72	12.27	15.82	19.37	22.92	26.46	30.01	33.56	35.33
3.66	0.81	1.14	1.47	1.80	2.13	2.46	2.79	3.12	3.28
150	8.97	12.61	16.26	19.91	23.55	27.20	30.85	34.49	36.32
3.81	0.83	1.17	1.51	1.85	2.19	2.53	2.87	3.20	3.37
156	9.45	13.29	17.14	20.98	24.83	28.67	32.51	36.36	38.28
3.96	0.88	1.23	1.59	1.95	2.31	2.66	3.02	3.38	3.56
162	9.69	13.63	17.58	21.52	25.46	29.40	33.35	37.29	39.26
4.11	0.90	1.27	1.63	2.00	2.37	2.73	3.10	3.46	3.65
168	10.18	14.32	18.46	22.60	26.74	30.87	35.01	39.15	41.22
4.27	0.95	1.33	1.71	2.10	2.48	2.87	3.25	3.64	3.83
174	10.42	14.66	18.90	23.13	27.37	31.61	35.85	40.09	42.21
4.42	0.97	1.36	1.76	2.15	2.54	2.94	3.33	3.72	3.92
180	10.90	15.34	19.77	24.21	28.64	33.08	37.52	41.95	44.17
4.57	1.01	1.42	1.84	2.25	2.66	3.07	3.49	3.90	4.10

Upper Numerals English Units/Lower Numerals Metric Units