
December 2023

SD-AS5D99HH-23.12



NOTES

- 1. $\frac{1}{2}$ " nominal deduction will be made to the opening size given.
- 2. Approximate shipping weight is 7.0 lbs./sq.ft.



Item #	Qty	Width	Height	Width	Height	Mullion	Туре	Location		A TONAL AS	
Item #		Openii	ng Size	Louve	er Size		Scre	eens		<u>Union Made</u>	
Arch. /	Arch. / Eng. :					EDR:		ECN:	Job:		
Contr	actor:										
Pr	oject:					Date:		DWN:	DWG:		
1020 F	1020 Prince Frederick Blvd. Suite 305 • Prince Frederick, MD 20687 • Phone: (570) 420-7079 • Fax: (570) 420-7078) 420-7078					


0 U V Ε S R

AS5D99HH

PERFORMANCE DATA

Pressure Drop: Free Area: Beginning Point of Water Penetration:

.31 in. w.g. (76.8 Pa) at 1250 fpm (6.35 m/s) and 8,850 scfm (4.18 scm/s) (intake). 7.08 sq.ft. (0.658 sq.m.) = 44.3% for 48"W x 48"H (1.22 m x 1.22 m) sample (AMCA Standard 500-L). Above 1250 fpm (6.35 m/s).



Intake air converted to standard air density. Tested to AMCA Standard 500-L, Figure 5.5.


		E	ree Area	sq.ft. (sc	<u>. meters</u>))
		Width in. (mm)				
		12" (305)	24" (610)	36" (914)	48" (1219)	60" (1524)
	12"	0.21	0.49	0.76	1.04	1.31
	(305)	(0.020)	(0.046)	(0.071)	(0.097)	(0.122)
	24"	0.63	1.43	2.24	3.04	3.85
	(610)	(0.059)	(0.133)	(0.208)	(0.282)	(0.358)
	36"	1.04	2.38	3.72	5.05	6.39
	(914)	(0.097)	(0.221)	(0.346)	(0.469)	(0.594)
л. (mm	48"	1.46	3.33	5.19	7.08	8.93
	(1219)	(0.136)	(0.309)	(0.482)	(0.658)	(0.830)
Height in. (mm)	60"	1.88	4.27	6.67	9.07	11.47
	(1524)	(0.175)	(0.397)	(0.620)	(0.843)	(1.066)
	72"	2.29	5.22	8.15	11.08	14.01
	(1829)	(0.213)	(0.485)	(0.757)	(1.029)	(1.302)
	84" (2134)	2.71 (0.252)	6.17 (0.573)	9.63 (0.895)	13.09 (1.216)	16.55 (1.538)
	96" (2438)	3.12 (0.290)	7.11 (0.661)	11.11 (1.032)	15.10 (1.403)	19.09 (1.774)

Wind-Driven Rain F	Penetration Classes	Discharge Loss Coefficient Classes			
Class Effectiveness		Class	Coefficient		
A	100% to 99%	1	0.4 and above		
В	98.9% to 95%	2	0.3 to 0.399		
С	94.9% to 80%	3	0.2 to 0.299		
D	Below 80%	4	0.199 and below		

Ratings do not include effects of a screen. Tests based on 48" x 48" sample size per AMCA Standard 511.

	Wind Driven Rain Performance								
Wind Velocity MPH (KPH)	Rainfall Rate in/h (mm/h)	Core Velocity FPM (m/s)	Ventilation Airflow CFM (cm/min)	Free Area Velocity FPM (m/s)	Effectiveness Ratio Percentage	Water Penetration Class	Coefficient of Discharge Class		
29 (46.7)	3 (76)	583 (3)	6,276 (3)	1,133 (5.8)	99.0%	Class A	Class 3		
Wind Velocity MPH (KPH)	Rainfall Rate in/h (mm/h)	Core Velocity FPM (m/s)	Ventilation Airflow CFM (cm/min)	Free Area Velocity FPM (m/s)	Effectiveness Ratio Percentage	Water Penetration Class	Coefficient of Discharge Class		
50 (80.5)	8 (203)	673 (3.5)	7,243 (239)	1,307 (6.68)	95.7%	Class B	Class 3		

Wind driven rain performance tests based on 1 m x 1 m (39.37" x 39.37") Louver with 7.08 sq.ft. (0.658 m²) free area.



1020 Prince Frederick Blvd. Suite 305 • Prince Frederick, MD 20687 • Phone: (570) 420-7079 • Fax: (570) 420-7078 AL-09-01-03